

NVPools, Inc.

14000 Thunderbolt Place, Suite E • Chantilly, Virginia 20151-3246 703.968.8800 • fax 703.230.6999 • www.nvpools.com

January 26, 2009

Mr. Marc Mordue Fairfax County Health Department 10777 Main Street Fairfax, VA 22030

Mr. Mordue:

At the request of John McCarthy, I am writing to inform you of the main drain suction inlet configurations of the following hydro therapy spas at the Fairfax County Parks. Each of the following has been tested by our company and all have main drain sumps that are cross connected. We have verified that both jet pumps and circulation pumps on each draw from the cross connected main drains. In addition, each spa currently has VGB approved drain grate covers installed.

•	Spring Hill Recreation Center	Dye Tested January 2009
•	Providence Recreation Center	Pressure Tested January 2009
•	Mount Vernon Recreation Center	Dye Tested January 2009
•	Oak Marr Recreation Center	Pressure Tested August 2009
•	Lee District	Dye Tested January 2009

Please let me know if you have any questions or need additional information regarding these facilities.

Sincerely,

Tim Thomas NVPools, Inc.

14000 Thunderbolt Place \

Suite E

Chantilly, VA 20151